



HELAGO-CZ, s.r.o.  
Commercial Register maintained by the Regional Court in Hradec  
Králové  
Section C, File 17879  
Kladská 1082  
500 03 Hradec Králové 3  
Company ID: 25 96 39 61, VAT: CZ 25963961  
Phone: 495 220 229, 495 220 394  
Fax: 495 220 154  
GSM gate: 602 123 096  
E-mail: info@helago-cz.cz  
Web: http://www.helago-cz.cz

**VBF.129.60 - One wing door - left**  
Order code: **8101.VBF12960**



Information about product price on demand

Parameters

Types of safety cabinets

Color

Interior equipment

Quantitative unit

Typ 90 - křídlové dveře

Světle šedá

Police

ks

- Safe and approved storage of hazardous materials in workrooms
- 90 minutes fire resistance cabinet in accordance with EN 14470-1 (Type 90)
- Cylinder locking (suitable for masterkey systems)
- The extraction air inlet is flush with the ceiling of the cabinet
- Adjusting aids to compensate for uneven floor
- Earthing link (standard)

### **Operation**

- Smooth, air-damped door closing
- Minimal effort: door opening - easy and safe
- Door closing system outside the storage compartment: increased protection of moving and safety relevant components against corrosion

### **Wing doors**

- 90° opening, interior of the cabinet completely visible

### **Door open arrest system (optional)**

- Holds door open and eases the storage and removal inside the cabinet
- Door open arrest system with an integrated, thermal release system (fusible link), automatic closing of the doors

### **Interior equipment**

- 3 adjustable shelves with inclination and pull-out protection, adjustable in different height in 32 mm - load on one shelf (uniform distributed) approx. 75 kg
- Easily removable bottom collection sump with three-sided lip seal for safe collection of leakage
- 1 perforated metal plate inserted at the bottom of collecting sump

### **Cabinet with width of 600 mm (VBF.129.60)**

- One wing door
- Dimensions w × d × h (mm): exterior approx. 600 × 615 × 1 298, interior approx. 450 × 520 × 1 070
- Weight: approx. 170 kg
- Bottom collection sump volume 22 l